



Certificate of Compliance

Certificate: 1473947 **Master Contract:** 221810
Project: 80215769 **Date Issued:** 2024-09-06
Issued to: Guide Valve Limited
51 Terecar Dr., Unit 1
Woodbridge, Ontario L4L 0B5
Canada
Attention: Kevin Yazdi

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by:
Vajira Sarathchandra
Vajira Sarathchandra, P. Eng.

PRODUCTS

Class 3371 03 VALVES (GAS) - Automatic - For Gas Appliances
Class 3371 83 VALVES (GAS) - Automatic-For Gas Appliances-Certified to U.S. Standards

Automatic Valve Assemblies for C/I Applications

TRADENAME: GVL or VCI

Model(s)	Size (Inlet X Outlet) (NPT)	Max Pressure (PSI)	Capacity (BTU/HR)
201F Series	1/4 x 1/4	600	See Mfr's Literature
	3/8 x 3/8	600	See Mfr's Literature
	1/2 x 1/2	600	See Mfr's Literature
	3/4 x 3/4	600	See Mfr's Literature
	1 x 1	600	See Mfr's Literature
	1-1/4 x 1-1/4	600	See Mfr's Literature



Certificate: 1473947

Master Contract: 221810

Project: 80215769

Date Issued: 2024-09-06

201F Series	1-1/2 x 1-1/2	600	See Mfr's Literature
	2 x 2	600	See Mfr's Literature
	1/4 x 1/4	600	See Mfr's Literature
	3/8 x 3/8	600	See Mfr's Literature
	1/2 x 1/2	600	See Mfr's Literature
	3/4 x 3/4	600	See Mfr's Literature
	1 x 1	600	See Mfr's Literature
	1-1/4 x 1-1/4	600	See Mfr's Literature
	1-1/2 x 1-1/2	600	See Mfr's Literature
	2 x 2	600	See Mfr's Literature

Rated for -40°C to 65°C applications, up to 600 PSI

TRADENAME: GVL or VCI

260 Series

Model(s)	Size (Inlet X Outlet) (NPT)	Max Pressure (PSI)	Capacity (BTU/HR)
260 Series	1/2 x 1/2	175	See Mfr's Literature
	3/4 x 3/4	175	See Mfr's Literature
	1 x 1	175	See Mfr's Literature
	1-1/2 x 1-1/2	175	See Mfr's Literature
	2 x 2	175	See Mfr's Literature

Rated for -40°C to 65°C, up to 175 PSI

TRADENAME: GVL or VCI

F200K Series

Model(s)	Size (Inlet X Outlet) (NPT)	Max Pressure (PSI)	Capacity (BTU/HR)
F200K Series	1/2 x 1/2	285 (or 125 if at -50°C)	See Mfr's Literature
	3/4 x 3/4	285 (or 125 if at -50°C)	See Mfr's Literature
	1 x 1	285 (or 125 if at -50°C)	See Mfr's Literature
	1-1/4 x 1-1/4	285 (or 125 if at -50°C)	See Mfr's Literature
	1-1/2 x 1-1/2	285 (or 125 if at -50°C)	See Mfr's Literature
	2 x 2	285 (or 125 if at -50°C)	See Mfr's Literature



Certificate: 1473947

Master Contract: 221810

Project: 80215769

Date Issued: 2024-09-06

	2-1/2 x 2-1/2	285	See Mfr's Literature
	3 x 3	285	See Mfr's Literature
	4 x 4	285	See Mfr's Literature
	6 x 6	125	See Mfr's Literature

Rated for -40°C to 65°C applications, up to 285 PSI (1/2" to 4" assemblies only) OR 125 PSI (6" assembly)

Rated for -50°C to 65°C applications, up to 125 PSI (1/2" to 2" assemblies only)

TRADENAME: GVL or VCI

Model(s)	Size (Inlet X Outlet) (NPT)	Max Pressure (PSI)	Capacity (BTU/HR)
F100 Series	8 x 8	175	See Mfr's Literature

Rated for -40°C to 65°C applications, up to 175 PSI, C/I

Notes:

1. The listed valve assemblies are certified for operation with specific actuators, solenoid valves, and limit switches. Refer to description section for further detail.
2. Electrical Rating: 120 VAC, 60 Hz, 0.12A Holding Current, 1.33A Operating Current; 24VDC; 12VDC
3. Ambient Temperature Range: General, -40°C to 65°C (-15°C for PAROFLUOR); F200K sizes 1/2" to 2" with Viton (FKM) or HNBR seals, -50°C to 65°C
4. Installation: Multipoise
5. Capacity & Cv: Refer to Manufacturer's Printed Instruction Manual

APPLICABLE REQUIREMENTS

CSA/AM CSA/ANSI Z21.21:19/CSA 6.5:19 (Sixth Edition) Upd.1:2021 - Automatic valves for gas appliances - Sixth Edition;
Update No. 1: March 2021



Certificate: 1473947


Project: 80215769

Master Contract: 221810

Date Issued: 2024-09-06

Notes:

Products certified under Class(es) C337103 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca



Products certified under Class(es) C337183 have been certified under CSA's ISO/IEC 17065 accreditation with the American National Standards Institute (ANSI). www.ansi.org





Supplement to Certificate of Compliance

Certificate: 1473947

Master Contract: 221810

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80215769	2024-09-06	Update report 1473947 (80093146) to standard edition CSA/ANSI Z21.21:23/CSA 6.5:23 (as per Inform Gas Products No. 519), addition of limit switches (MFR- Topworx, Models DXP-M21GNEB & DXP-T21GNEB) and addition of valves (MFR AVC, P01 Series & MFR ASCO, Models TBD)
80093146	2022-10-15	Certification of Automatic Gas Valve Assembly Series (Sizes: 1/2", 3/4", 1", 1-1/2" & 2"), 260 series. Add new actuator to currently approved valve assemblies in 201 series and F200K series. Testing performed under WMTC program.
70043192	2016-03-30	Approve F200K automatic valve assemblies sizes 1/2" to 2" to -50°C
1924833	2007-07-19	Update report to include revised ASCO & Controlink limit switch model numbers
1867468	2007-01-05	Update Certification to Larger Size Actuators on Valves upto 4"
1837787	2006-10-27	Update to 1473947 to add 300# Flanges
1661392	2005-05-24	Alternate limit switches, Controlink XAB Series.
1586980	2005-03-16	Alternate seat and seal materials, 201F Series (1/4" thru 2") and F200K Series (1/2" thru 6").
1473947	2004-03-18	C/US Certification of Automatic Gas Valves, 201 Series (1/4" thru 2"), F200K Series (1/2" thru 4").